

### DJUSD K-12 School Site Drinking Water Lead Testing Results

School Site	Testing Locations	Lead Concentration (ppb)		State Threshold	Additional Action
		Low	High		
Birch Lane	5	0	0	15 ppb	None required (<15 ppb)
Cesar Chavez	5	0	0	15 ppb	None required (<15 ppb)
Fairfield	N/A	N/A	N/A	15 ppb	No domestic water currently at site due to CR6 issue.
Korematsu	5	0	0	15 ppb	None required (<15 ppb)
Montgomery	5	0	0	15 ppb	None required (<15 ppb)
North Davis	5	0	0	15 ppb	None required (<15 ppb)
Patwin	3	0	0	15 ppb	None required (<15 ppb)
Pioneer	4	0	1.4	15 ppb	None required (<15 ppb)
Willett	5	0	1.6	15 ppb	None required (<15 ppb)
Emerson	5	0	7.4	15 ppb	None required (<15 ppb)
Harper	5	0	0	15 ppb	None required (<15 ppb)
Holmes	5	0	0	15 ppb	None required (<15 ppb)
Davis Senior High	5	0	0	15 ppb	None required (<15 ppb)
Valley Oaks Campus	5	0	4.5	15 ppb	None required (<15 ppb)
King High	2	0	0	15 ppb	None required (<15 ppb)
DSIS	5	0	3.1	15 ppb	None required (<15 ppb)

*Note: All samples taken no earlier than October 12, 2017. Testing was for lead only. No testing was completed for other elements.*

*ppb = parts per billion*